

Annexure C


PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 85/KAB

Dated: 02/07/2024

It is certified that an inspection team headed by **Mr. Manish Thacker**
(Name of Officers with designation) from **Technical Manager IMC cum Incharge Chemist PHED**
inspected the **Bellwether International School at Keshar Bardi, Mhow Dist. Indore (MP)** on
02/07/2024 (date of inspection) and on the basis of Water Test Report (Attached) bearing no
CH/135 dated 02/07/2024 of **Water Testing Laboratory, Indore** (PHED Lab) certified that the
Bellwether International School has safe drinking water facilities for the students and members of
staff of the institution. School is also maintains the hygienic sanitation condition in the school
building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 01/07/2025


Mr. Manish Thacker
Incharge Chemist
WTL M.D. No. 2 PHE/IMC
INDORE (M.P.)

To
Bellwether International School
Keshar Bardi, Mhow Dist. Indore (MP)

Water Testing Laboratory
Indore Municipal Corporation Indore M.P.

Email: Waterlabimc@outlook.com, EE_narmada@rediffmail.com

Sample from : Principal	Report No. : CH/24-25/135
Bellwether International School	Date of Collection : 28/06/2024
Keshar Bardi, Mhow, Dist.Indore(MP)	Date of Receipt : 28/06/2024
Description : Volume 1ltr.	Date of Report : 02/07/2024
Lab staff	Time of Receipt : 13.15 Hrs

S.No.	Tests	Units	Desirable limit Is-10500-12	Permissible Limit Is-10500-12	Results
A.	PHYSICAL :				
1.	Temperature	°C	-	-	25
2.	Colour	Platinum Cobalt Scale	5	25	0
3.	Odour		Agreeable	Agreeable	Agreeable
4.	Turbidity	N.T.U.	1.0	5	0.8
5.	pH	pH scale	7.0-8.5	No Relaxation	7.32
B.	CHEMICAL :				
1.	Alkalinity (As CaCo3)	mg/l	200	600	16
2.	Total Hardness (As CaCo3)	mg/l	300	600	28
3.	Calcium	mg/l	75	200	3.8
4.	Magnesium	mg/l	30	150	2.4
5.	Chloride (As Cl)	mg/l	200	1000	5
6.	Sulphate (As SO4)	mg/l	200	400	6.1
7.	Nitrate (As NO3)	mg/l	45	45	2.2
8.	Total Dissolved Solids	mg/l	500	2000	80
9.	Manganse	mg/l	0.1	0.3	0.0
10.	Fluoride (As F)	mg/l	1.0	1.5	0.1
11.	Residual Chlorine	mg/l	0.2	1.0	----
12.	Iron (As Fe)	mg/l	0.1	1.0	0.06
Special Test					
13	Fecal Coliform	CFU/100ml	0	0	0

Remark : Result of tested parameter are within the desirable limit.

I. M. C. Musakhedi
Technical Manager
Water Testing Laboratory
I. M. C. Musakhedi,
INDORE (M.P.)