

Water Testing Laboratory

Indore Municipal Corporation, Musakhedi, Indore


Test Certificate

Sample from : Bellwether International School Keshar Bardi, Mhow Dist Indore Sample Details 1ltr Bottle by your self	Report No:CH/25/248
	Date of Collection :22/07/25
	Date of Receipt : 22/07/25
	Completion date : 25/07/25
	Time of Receipt :4.30

S.No.	Tests	Units	Desirable Limit IS-10500-12	Permissible Limit IS-10500-12	Results
A. Organoleptic and Physical Parameters					
1.	Temperature	°C	----	----	25.7
2.	Colour	Platinum Cobalt Scale	5	15	0
3.	Odour		Agreeable	Agreeable	Agreeable
4.	Turbidity	N.T.U.	1	5	0.25
5.	Total Dissolved Solids	mg/l	500	2000	84
B. General Parameters Concerning Substances Undesirable in Excessive Amounts					
6.	pH	pH scale	6.5-8.5	No Relaxation	7.21
7.	Alkalinity	mg/l	200	600	32
8.	Total Hardness	mg/l	300	600	31
9.	Chloride	mg/l	250	1000	2
10.	Fluoride	mg/l	1.0	1.5	<0.05
11.	Iron	mg/l	0.3	1.0	<0.05
12.	Calcium	mg/l	75	200	1.2
13.	Magnesium	mg/l	30	100	4.8
14.	Sulphate	mg/l	200	400	3.2
15.	Nitrate	mg/l	45	No Relaxation	1.34
C. Coliform Count					
19.	Thermo tolerant Coliform Bacteria	CFU/100ml	0	0	0

'BDL' Below determination limit

Remark:- Tested parameter confirms desirable limit hence safe for drinking.


Incharge Chemist
 Authorized Signatory
 WTL M.D. No. 2 PHE/IMC
 INDORE (M.P.)




SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 85/LA13

Dated: 25/7/25

It is certified that an inspection team headed by Mr. Praven Sharma from Assistant Engineer, Sub Division, PHED Indore (MP) inspected the Bellwether International School at Keshar Bardi, Mhow Dist. Indore (MP) on 22/07/2025 (date of inspection) and on the basis of Water Test Report bearing no CH/25/248 dated 25/07/2025 of Water Testing Laboratory, Indore (PHED Lab) certified that the Bellwether International School has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 01 Year


Assistant Engineer
Maint. Sub Dn. No. 8
PHE, INDORE (M.P.)

To
Principal,
Bellwether International School
Keshar Bardi, Mhow
Dist. Indore (MP)